



Aqua Solutions, Inc.
6913 Highway 225
Deer Park, TX, 77536
281/479-2569
Certificate of Analysis / QC Results
Customer PO # :

Test	Target/UOM	Range	Result
Packaged Product: K4601 KEROSENE DEODORIZED			
VIS @ 40 DEG C, ASTM D-0445, CST	CST		1.90 CST
Sample ID			
Tested 03/24/23			
Tester TBUR			
Recorded 03/24/23			
GRAVITY, API @ 60 DEC F	46.0 DEG F	43.0 - 49.0	46.8
Sample ID			
Tested 03/24/23			
Tester TBUR			
Recorded 03/24/23			
GRAVITY IN POUNDS/GAL @ 60F	LB/GAL		6.616
Sample ID			
Tested 03/24/23			
Tester TBUR			
Recorded 03/24/23			
FLASH PMCC,C	MIN 71C DEG C		96 C
Sample ID			
Tested 03/24/23			
Tester TBUR			
Recorded 03/24/23			
FLASH PMCC,F	MIN 160F DEG F		204 F
Sample ID			
Tested 03/24/23			
Tester TBUR			
Recorded 03/24/23			
POUR POINT,C	-40C DEG C		-37 C
Sample ID			
Tested 03/24/23			
Tester TBUR			
Recorded 03/24/23			
POUR POINT,F	-40F DEG F		-35 F
Sample ID			
Tested 03/24/23			
Tester TBUR			
Recorded 03/24/23			
COLOR (SAYBOLT)	MIN +28 COLOR		30
Sample ID			
Tested 03/24/23			
Tester TBUR			
Recorded 03/24/23			



Aqua Solutions, Inc.
6913 Highway 225
Deer Park, TX, 77536
281/479-2569
Certificate of Analysis / QC Results
Customer PO # :

WATER CONTENT	MAX 500PPM %	51 PPM
Sample ID		
Tested 03/24/23		
Tester TBUR		
Recorded 03/24/23		
DISTILLATION,IBP F	MIN 400F DEG F	433 F
Sample ID		
Tested 03/24/23		
Tester TBUR		
Recorded 03/24/23		
DISTILLATION,5% RECOVERED,F	DEG F	439 F
Sample ID		
Tested 03/24/23		
Tester TBUR		
Recorded 03/24/23		
DISTILLATION,50% RECOVERED,F	DEG F	446 F
Sample ID		
Tested 03/24/23		
Tester TBUR		
Recorded 03/24/23		
DISTILLATION,95% RECOVERED,F	DEG F	471 F
Sample ID		
Tested 03/24/23		
Tester TBUR		
Recorded 03/24/23		
DISTILLATION,DRY POINT,F	DEG F	472 F
Sample ID		
Tested 03/24/23		
Tester TBUR		
Recorded 03/24/23		
DISTILLATION,END POINT,F	MAX 514F DEG F	477 F
Sample ID		
Tested 03/24/23		
Tester TBUR		
Recorded 03/24/23		
SPECIFIC GRAVITY @ 60/60 DEG F	SPEC GRAVITY	0.7936
Sample ID		
Tested 03/24/23		
Tester TBUR		
Recorded 03/24/23		

Lot # 308202
Made 03/23/23



Aqua Solutions, Inc.
Ph: 281-479-2569
Fax: 281-479-2790
P.O. Box 70
Deer Park, TX 77536

Website: www.aquasolutions.org

Page: 3

Date: 03/24/23 at 1:52 PM

Aqua Solutions, Inc.
6913 Highway 225
Deer Park, TX, 77536
281/479-2569
Certificate of Analysis / QC Results
Customer PO # :

Quality Manager