



Aqua Solutions, Inc.
6913 Highway 225
Deer Park, TX, 77536
281/479-2569
Certificate of Analysis / QC Results
Customer PO # :

Test	Target/UOM	Range	Result
Packaged Product: K4601 KEROSENE DEODORIZED			
VIS @ 40 DEG C, ASTM D-0445, CST	CST		1.90 CST
Sample ID			
Tested 05/15/23			
Tester TBUR			
Recorded 05/15/23			
GRAVITY, API @ 60 DEC F	46.0 DEG F	43.0 - 49.0	46.8
Sample ID			
Tested 05/15/23			
Tester TBUR			
Recorded 05/15/23			
GRAVITY IN POUNDS/GAL @ 60F	LB/GAL		6.616
Sample ID			
Tested 05/15/23			
Tester TBUR			
Recorded 05/15/23			
FLASH PMCC,F	MIN 160F DEG F		204 DEG F
Sample ID			
Tested 05/15/23			
Tester TBUR			
Recorded 05/15/23			
POUR POINT,F	-40F DEG F		-25 DEG F
Sample ID			
Tested 05/15/23			
Tester TBUR			
Recorded 05/15/23			
COLOR (SAYBOLT)	MIN +28 COLOR		30
Sample ID			
Tested 05/15/23			
Tester TBUR			
Recorded 05/15/23			
DISTILLATION,IBP F	MIN 400F DEG F		434 DEG F
Sample ID			
Tested 05/15/23			
Tester TBUR			
Recorded 05/15/23			
DISTILLATION,5% RECOVERED,F	DEG F		441 DEG F
Sample ID			
Tested 05/15/23			
Tester TBUR			
Recorded 05/15/23			



Aqua Solutions, Inc.
 Ph: 281-479-2569
 Fax: 281-479-2790
 P.O. Box 70
 Deer Park, TX 77536
 Website: www.aquasolutions.org

Aqua Solutions, Inc.
6913 Highway 225
Deer Park, TX, 77536
281/479-2569
Certificate of Analysis / QC Results
Customer PO # :

DISTILLATION,50% RECOVERED,F	DEG F	448 DEG F
Sample ID		
Tested	05/15/23	
Tester	TBUR	
Recorded	05/15/23	
SPECIFIC GRAVITY @ 60/60 DEG F	SPEC GRAVITY	0.7936
Sample ID		
Tested	05/15/23	
Tester	TBUR	
Recorded	05/15/23	
Lot #	313204	
Made	05/12/23	

Richard [Signature]

Quality Manager