



Aqua Solutions, Inc.
6913 Highway 225
Deer Park, TX, 77536
281/479-2569
Certificate of Analysis / QC Results
Customer PO # :

Test	Target/UOM	Range	Result
Packaged Product: K4601 KEROSENE DEODORIZED			
VIS @ 40 DEG C, ASTM D-0445, CST	CST		1.90 CST
Sample ID			
Tested 05/25/23			
Tester TBUR			
Recorded 05/25/23			
GRAVITY, API @ 60 DEC F	46.0 DEG F	43.0 - 49.0	46.8
Sample ID			
Tested 05/25/23			
Tester TBUR			
Recorded 05/25/23			
GRAVITY IN POUNDS/GAL @ 60F	LB/GAL		6.616
Sample ID			
Tested 05/25/23			
Tester TBUR			
Recorded 05/25/23			
FLASH PMCC,F	MIN 160F DEG F		204 DEG F
Sample ID			
Tested 05/25/23			
Tester TBUR			
Recorded 05/25/23			
POUR POINT,F	-40F DEG F		-25 DEG F
Sample ID			
Tested 05/25/23			
Tester TBUR			
Recorded 05/25/23			
COLOR (SAYBOLT)	MIN +28 COLOR		30
Sample ID			
Tested 05/25/23			
Tester TBUR			
Recorded 05/25/23			
WATER CONTENT	MAX 500PPM %		30 PPM
Sample ID			
Tested 05/25/23			
Tester TBUR			
Recorded 05/25/23			
DISTILLATION,IBP F	MIN 400F DEG F		434 DEG F
Sample ID			
Tested 05/25/23			
Tester TBUR			
Recorded 05/25/23			



Aqua Solutions, Inc.
6913 Highway 225
Deer Park, TX, 77536
281/479-2569
Certificate of Analysis / QC Results
Customer PO # :

DISTILLATION,5% RECOVERED,F	DEG F	441 DEG F
Sample ID		
Tested 05/25/23		
Tester TBUR		
Recorded 05/25/23		
DISTILLATION,50% RECOVERED,F	DEG F	448 DEG F
Sample ID		
Tested 05/25/23		
Tester TBUR		
Recorded 05/25/23		
DISTILLATION,95% RECOVERED,F	DEG F	467 DEG F
Sample ID		
Tested 05/25/23		
Tester TBUR		
Recorded 05/25/23		
DISTILLATION,DRY POINT,F	DEG F	474 DEG F
Sample ID		
Tested 05/25/23		
Tester TBUR		
Recorded 05/25/23		
DISTILLATION,END POINT,F	MAX 514F DEG F	477 DEG F
Sample ID		
Tested 05/25/23		
Tester TBUR		
Recorded 05/25/23		
SPECIFIC GRAVITY @ 60/60 DEG F	SPEC GRAVITY	0.7936
Sample ID		
Tested 05/25/23		
Tester TBUR		
Recorded 05/25/23		

Lot # 314405

Made 05/24/23

Quality Manager