



Aqua Solutions, Inc.
6913 Highway 225
Deer Park, TX, 77536
281/479-2569
Certificate of Analysis / QC Results
Customer PO # :

Packaged Product: K4601 KEROSENE DEODORIZED			
Test	Target/UOM	Range	Result
VIS @ 40 DEG C, ASTM D-0445, CST	CST		1.89
Sample ID			
Tested 02/13/24			
Tester TBUR			
Recorded 02/13/24			
GRAVITY, API @ 60 DEC F	46.0 DEG F	43.0 - 49.0	45.9
Sample ID			
Tested 02/13/24			
Tester TBUR			
Recorded 02/13/24			
GRAVITY IN POUNDS/GAL @ 60F	LB/GAL		6.650
Sample ID			
Tested 02/13/24			
Tester TBUR			
Recorded 02/13/24			
FLASH PMCC,F	MIN 160F DEG F		202F
Sample ID			
Tested 02/13/24			
Tester TBUR			
Recorded 02/13/24			
POUR POINT,F	-40F DEG F		-30F
Sample ID			
Tested 02/13/24			
Tester TBUR			
Recorded 02/13/24			
COLOR (SAYBOLT)	MIN +28 COLOR		30
Sample ID			
Tested 02/13/24			
Tester TBUR			
Recorded 02/13/24			
WATER CONTENT	MAX 500PPM %		52 PPM
Sample ID			
Tested 02/13/24			
Tester TBUR			
Recorded 02/13/24			
DISTILLATION,IBP F	MIN 400F DEG F		430F
Sample ID			
Tested 02/13/24			
Tester TBUR			
Recorded 02/13/24			



Aqua Solutions, Inc.
6913 Highway 225
Deer Park, TX, 77536
281/479-2569

Certificate of Analysis / QC Results

Customer PO # :

DISTILLATION,5% RECOVERED,F	DEG F	438F
Sample ID		
Tested 02/13/24		
Tester TBUR		
Recorded 02/13/24		
DISTILLATION,50% RECOVERED,F	DEG F	446F
Sample ID		
Tested 02/13/24		
Tester TBUR		
Recorded 02/13/24		
DISTILLATION,95% RECOVERED,F	DEG F	467F
Sample ID		
Tested 02/13/24		
Tester TBUR		
Recorded 02/13/24		
DISTILLATION,DRY POINT,F	DEG F	473F
Sample ID		
Tested 02/13/24		
Tester TBUR		
Recorded 02/13/24		
DISTILLATION,END POINT,F	MAX 514F DEG F	475F
Sample ID		
Tested 02/13/24		
Tester TBUR		
Recorded 02/13/24		
SPECIFIC GRAVITY @ 60/60 DEG F	SPEC GRAVITY	0.7976
Sample ID		
Tested 02/13/24		
Tester TBUR		
Recorded 02/13/24		

Lot # 403901

Made 02/08/24

Quality Manager